



- Notes**
1. ALL DIMENSIONS ARE IN MILLIMETRES, UNLESS NOTED OTHERWISE.
  2. ANY ELEMENTS OR OBJECTS THAT ARE NOT DIMENSIONED SHALL NOT BE SCALED UNDER ANY CIRCUMSTANCES. THEY SHALL BE AGREED/CONFIRMED WITH THE EMPLOYER.
  3. TENDER ISSUE DRAWINGS SHALL BE READ IN CONJUNCTION WITH THE TERMINAL TO EMPLOYER'S REQUIREMENTS AND RELATED CONTRACT DOCUMENTS.
  4. THE CONTRACTOR MAY DEVIATE FROM THE PROPOSED SERVICE CORRIDORS PROVIDED THAT ALL CLASHES ARE AVOIDED WITH OTHER SERVICES. SHOULD THERE BE ANY DEVIATIONS FROM THE BUILDING PERMIT DESIGN, IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO REPLY FOR THE BUILDING PERMIT.
  5. SERVICE INSPECTION CHAMBERS SHALL BE LOCATED AWAY FROM ALL TERMINAL ROAD LANES WHERE POSSIBLE WITHIN THE PROPOSED SERVICE CORRIDORS.
  6. ALL DETAILS SHOWN ARE INDICATIVE ONLY. CONTRACTOR SHALL CARRY OUT HIS OWN DETAILED DESIGN TO DETERMINE THE EXACT FIRE AND POTABLE WATER NETWORK TO COMPLY WITH THE EMPLOYER'S REQUIREMENTS.
  7. FIRE HYDRANTS ARE SPACED TO SUIT THE FUTURE CONTAINER TERMINAL. CONTRACTOR TO CONSULT WITH HIS OWN FIRE SAFETY EXPERT TO CONFIRM THE LOCATION OF FIRE HYDRANT SPACING AND FLOW RATES FOR THE OFFSHORE WIND TERMINAL.

**LEGEND**

- POTABLE WATER ROUTING
- FIRE WATER ROUTING
- WP QUAY SIDE WATER BUNKERING POINT
- FH FIRE HYDRANT

**NOT FOR CONSTRUCTION**

**TENDER**

REV	Date	Description	Drawn	CHK	APP
P04	08/12/23	TENDER ISSUE	AS	AT	CSJ
P03	21/11/23	TENDER ISSUE	AS	AT	CSJ
P02	31/10/23	TENDER ISSUE	AS	AT	CSJ
P01	18/09/23	TENDER ISSUE	AS	AT	CSJ
P0	11/08/23	TENDER DRAFT	AS	AT	CSJ

Client ISTRANA / Baltic Hub Container Terminal Sp. z o.o.

**Baltic Hub** ISTRANA/ Baltic Hub Container Terminal Sp. z o.o. ul. Kontenerowa 7, 80-601 Gdańsk

Project **BALTIC HUB T5 OFFSHORE WIND TERMINAL PROJECT**

Drawing Title **T5 POTABLE & FIRE WATER ROUTES**

HaskoningDHV Polska Sp. z o.o. ul. Dzielna 60 01-029 Warszawa

**Royal HaskoningDHV**  
Enhancing Society Together

Drawn DD	Checked AT	Approved CSJ
Date 17.07.23	Scale 1:1000	REF.
Drawing Number PC1063-RHD-T5-OW-DR-EL-6003	Suitability S4	Revision P04

Potable water connection to site compound and buildings to be determined by the contractor

FIRE AND POTABLE WATER NETWORK DESIGN SHOWN MUST BE VERIFIED BY THE CONTRACTOR AND IS FOR INFORMATION ONLY.

